




DESC: 14/12 CABLE 105C 600V			DWG NO: FCAB1412-002	ITEM	SPECS.	
SCALE:10x	DATE:10/20/11	DR. BY: DPL	NWI P/N: FCAB1412-002	A.	14 GAUGE 41x30TC BUNCHED	
CUSTOMER: IEWC		CUSTOMER P/N: T12141015-1/PRINT			B.	30 MILS PVC INSULATION PER UL AWM 1015 27 MILS MIN. PVC INSULATION O.D. .135±.002"
<p><i>Information of Northwire, Inc. (and its subsidiary) and shall not be used, disclosed or reproduced, without the written consent of Northwire, Inc. (and its subsidiary).</i></p> <p><i>This document may be subject to the International Traffic in Arms Regulation (ITAR) and the Export Administration Regulations (EAR). Technical data to Foreign Persons in the course of employment with U.S. contractors is considered an export and is subject to the ITAR and EAR export licensing requirements/regulations.</i></p>				C.	POLYESTER LACING TAPE SPACING ON TAPE: 6 INCHES	
				CABLE IS NOT UL OR CSA APPROVED		
				BLACK INK PRINTED NUMBERS TOWER PRINTED; SIX INCH SPACING BETWEEN NUMBERS		



ELECTRICAL REQUIREMENTS:  
NONE SPECIFIED

MECHANICAL REQUIREMENTS:  
NONE SPECIFIED

CORE DIMENSIONS FOR INTERNAL USE ONLY

WAS BARE COPPER	D	3/9/13	DPL		
WAS TWO #11 ON DRAWING	C	11/4/11	DPL		
ADDED SPACING ON TAPE WRAP	B	10/31/11	DPL		
REVISION RECORD	A	10/20/11	DPL		
REVISION RECORD	REV	REV DATE	APR 1 APR 2	QA R	