
PRODUCT SPECIFICATION DRAWING

Proprietary Information not to be reproduced

Product Title:

1/C 1 AWG, EXANE INSULATION, (UL) RHH / RHW CSA RW90



NOMINAL DIAMETER CONSTRUCTION: (1 REQUIRED) 1 AWG 225/24 Tinned Copper

(Inches) (mm)0.385 9.779

Irradiation Cross-Linked Exane (Polyolefin) 2.0 INSULATION: Minimum Average Wall Thickness 0.090 inches

0.570 14.478 ± 0.381 ±.015

Dark Gray COLOR: <u>3.0</u>

CONDUCTOR:

1.0

Insulated conductor is printed in ink with contrasting color as follows: MARKING: 4.0

" P & H MINING EQUIPMENT INC. XLPO-125 1/C 1 AWG E31697 2000V (UL) RHH/RHW PR I -CSA RW90 -40°C 1000V LL14444 FT4 "

TECH DATA: 5.0

2000 V (RMS) Voltage Rating: 5.1

380 lb/1,000 ft, Nominal Weight: 5.2

105356

SURPRENANT CABLE CORPORATION ENGINEERED WIRE AND CABLE	Phone: (800) 327 - 7625 Fax: (860) 653 - 8301	Drawn By: P. Robinson	Date: 5/9/08	Page: 1 of 1
	Part Number:	Reviewed By: W. Drabek	Revision: 0	DWG Number: TD-006559