


232 Sherman Street Gardner, MA 01440 Phone: 978-632-0900 Fax: 978-630-1872 Visit us on our website: www.dataguidecable.com



2 CONDUCTOR Control CABLE Tissue Binder Tape AND PVC JACKET

COMPONENT A

CONDUCTORS (2 total):

18 AWG 19/30 Bare Copper Insulated with 0.022" Nominal Wall of PVC to a Nominal O.D. of 0.092"

COLORS:

Black, Red

FINAL CABLING:

3.00" Nominal Left-Hand Directional Lay

Component A Cabled Together Binder: Tissue Tape, 25% Overlap

FINAL JACKET:

Material: PVC

Color: RAL 7001 Gray Wall Thickness: 0.047"

Finished Cable Diameter: 0.284"

Print Legend: <Company Logo> 18AWG/2C E# UL AWM TYPE 2586 105C 600V --- LL# CSA AWM I/II A/B 105C


600V FT4

LISTING / AGENCY APPROVAL

UL AWM 2586 600V 105C CSA AWM I/II A/B 105C 600V FT4

REVISION HISTORY


0	4-3-2024	RMB	First Issue
Cus	stomer Number		
D.G	6. Part Number		24D1-2
Pre	pared By: RMB		
Rev	riewed By:		







232 Sherman Street Gardner, MA 01440 Phone: 978-632-0900 Fax: 978-630-1872 Visit us on our website; <u>www.dataguidecable.com</u>



4 CONDUCTOR Control CABLE Tissue Binder Tape AND PVC JACKET

COMPONENT A

CONDUCTORS (4 total):

18 AWG 19/30 Bare Copper Insulated with 0.022" Nominal Wall of PVC to a Nominal O.D. of 0.092"

COLORS:

Black, Red, White, Green/Yellow

FINAL CABLING:

3.50" Nominal Left-Hand Directional Lay Component A Cabled Together Binder: Tissue Tape, 25% Overlap

FINAL JACKET:

Material: PVC

Color: RAL 7001 Gray Wall Thickness: 0.047"

Finished Cable Diameter: 0.322"

Print Legend: <Company Logo> 18AWG/4C E# UL AWM
TYPE 2586 105C 600V --- LL# CSA AWM I/II A/B 105C

600V FT4

LISTING / AGENCY APPROVAL

UL AWM 2586 600V 105C CSA AWM I/II A/B 105C 600V FT4

REVISION HISTORY

0	4-3-2024	RMB	First Issue
Cus	tomer Number		
D.G	. Part Number		24D1-3
Pre	pared By: RMB		
Rev	riewed By:		