

29 HANOVER ROAD FLORHAM PARK , NJ 07932 (800) 774-3539

## Customer Specification


Lapp Spec#	812915	Date: 01/17/2012
Eabb oboo "	012010	Date: 0 1/ 1 // 20 12

Description

Product Name: 16AWG/7C Tray II Special

16AWG Multi -conductor unshielded Flexible Tray cable , bare copper conductors , PVC/Nylon insulation , black conductors with white numbers plus green /yellow (30% stripe width), Overall flame and oil resistant PVC jacket , UL Type TC - ER 90C 600V NEC Article 336, MTW, DP-1, Wind Turbine Tray Cable 1000V 90C Dry, AWM 1000V & cUL Type CIC /TC, CSA AWM 90C 1000V FT4, Conforms to LVD 2006/95/EC (low voltage directive) and EN 2002/95/EC (RoHS Directive).

\* All dimensions are nominal and inches unless specified [] = mm \*



## 1.0 CABLE INFORMATION:

Same as Olflex Tray II P/N 221607 **except** with yellow jacket. All else the same.

## 2.0 FINISH PRODUCT REQUIREMENT

In Accordance with CE Directive, PS-001 & WS-001 Specifications & Procedures

Customer Signature:	Date
Company:	