

Construction

- A. Tinned Copper Strand: 36 AWG
- B. Strand Construction: See below
- C. Insulated with PVC, 80°C, 300 volts
 - 1. Wall thickness: See below
 - 2. Color: To be specified
 - 3. UL 1662

PART NUMBER	AWG SIZE	STRAND CONSTRUCTION	NO. OF ENDS	CIRC. MILS.	MIN. WALL THICKNESS	NOM. OVERALL O.D.	NOM. CARRYING CAPACITY AMPS
CW 3563-02	18	7x9x36	63	1,575	.015"	.082"	12
CW 3563-01	16	7x15x36	105	2,625	.015"	.100"	19
CW 3563-0	14	7x24x36	168	4,200	.020"	.128"	30
CW 3563-2	12	7x37x36	259	6,475	.020"	.148"	35
CW 3563-4	10	7x59x36	413	10,325	.020"	.175"	50
CW 3563-6	8	7x95x36	665	16,625	.030"	.233"	70
CW 3563-8	7	7x119x36	833	20,825	.030"	.253"	80
CW 3563-10	6	7x150x36	1,050	26,250	.030"	.276"	95
CW 3563-12	4	7x7x34x36	1,666	41,650	.030"	.349"	125
CW 3563-14	2	7x7x54x36	2,646	66,150	.030"	.422"	170
CW 3563-16	1	7x7x68x36	3,332	83,300	.040"	.488"	195
CW 3563-18	1/0	7x7x86x36	4,214	105,350	.040"	.538"	230
CW 3563-20	2/0	7x7x108x36	5,292	132,300	.050"	.614"	265
CW 3563-22	3/0	19x7x51x36	6,783	169,575	.060"	.679"	310
CW 3563-24	4/0	19x7x64x36	8,512	212,800	.080"	.789"	360

Jacket color to be specified.

