



ATLAS WIRE LLC.
 9525 RIVER STREET
 SCHILLER PARK, ILLINOIS 60176
 (847) 678-1210
 (847) 678-1281 FAX
 www.atlaswirecorp.com



Atlas Wire, LLC
 Registered to ISO9001 and TS16949
 Schiller Park, IL 60176
 Reference No. 10000854
 Tucson, AZ 85714
 Reference No. 10003647

MATERIAL SPECIFICATION SHEET

#26 19/38 TC 1/3" UNILAY .010" PVC
RoHS COMPLIANT
UL AWM STYLE 1061 80c – 300v VW1
UL AWM STYLE 10002 105c – 300v VW1
CSA AWM I A/B 80c – 300v FT1 SR PVC

| | |
|-------------------|--|
| CONDUCTOR: | #26 19/38 TINNED COPPER 1/3" UNILAY NOMINAL O.D. .020" APPROXIMATE CIRCULAR MILL AREA 299 WEIGHT PER THOUSAND FEET 1.0# BASIC SPECIFICATION ASTM B-8 ASTM B-286 |
| PVC: | TEMPERATURE RATING 105c VOLTAGE RATING 300v ELONGATION 300% SPECIFIC GRAVITY 1.34 DUROMETER (SHORE) 60 (D) TENSILE STRENGTH 3,210 PSI OXYGEN INDEX 28 BRITTLE POINT -8c SPARK TESTED 5,700 |
| VOLTS | FINISHED O.D. .039" WEIGHT PER THOUSAND FEET 1.57# |
| USE: | INTERNAL WIRING IN BOOKKEEPING, ACCOUNTING TIME RECORDING MACHINES, OR ELECTRONIC EQUIPMENT IF WITHIN A CHASIS OR PROTECTED FROM MECHANICAL INJURY. |

info@atlaswirecorp.com