



ATLAS WIRE LLC.
 9525 RIVER STREET
 SCHILLER PARK, ILLINOIS 60176
 (847) 678-1210
 (847) 678-1281 FAX
 www.atlaswirecorp.com



Atlas Wire, LLC
 Registered to ISO9001 and TS16949
 Schiller Park, IL 60176
 Reference No. 10000854
 Tucson, AZ 85714
 Reference No. 10003647

MATERIAL SPECIFICATION SHEET

#14 19/27 TC .010" PVC .004" NYLON RoHS COMPLIANT MIL-DTL-16878/17 TYPE BN 105c – 600v

CONDUCTOR:	#14 19/27 TINNED COPPER 1-1/4" UNILAY NOMINAL O.D. .071" APPROXIMATE CIRCULAR MILL AREA 3,831 WEIGHT PER THOUSAND FEET 11.60# BASIC SPECIFICATION ASTM B-8 ASTM B-286
PVC:	TEMPERATURE RATING 105c VOLTAGE RATING 600 VOLTS ELONGATION 300% AVG. SPECIFIC GRAVITY 1.34 DUROMETER (SHORE) 47 (D) COLD BEND TEST -54 TENSILE STRENGTH 3000 PSI AVG SPARK TESTED 5,700 VOLTS FINISHED O.D. .090" WEIGHT PER 1,000 FEET 13.12#
NYLON:	ELONGATION 300% TENSILE STRENGTH 11,500 PSI AVG SPECIFIC GRAVITY 1.13 OVERALL DIAMETER .098" WEIGHT PER M FEET 13.79#
REVISION:	MIL-DTL-16878H - PRINT REQUIRED* * OUR STANDARD IS PRINTED, IF NO PRINTING IS PREFERRED PLEASE CALL THAT OUT AT TIME OF ORDER.
STANDARD EXCEPTION:	HEAT RESISTANCE TEST PASSES 136c FOR 96 HOURS. PASSES HORIZONTAL FLAME TEST PER UL.

info@atlaswirecorp.com