



DECA CABLES INC.
150 North Murray Street
P.O. Box 777
Trenton, Ontario K8V 5W6
Canada

Telephone: (613) 392-3585

Fax: (613) 392-7908

ISO 9002 - 1994

PRODUCT DATA SHEET

PART NUMBER	76-433
DESCRIPTION	AWM SR/PVC 3PR 22/7T 65% T CSA FT4
CONDUCTOR	22 AWG TINNED COPPER
STRANDING	7 X 0.0100"
CONDUCTOR DIAMETER	0.030"
RESISTANCE	16.6 OHMS/1000FT.
INSULATION	SEMI RIGID PVC
INSULATION THICKNESS	0.009"
INSUL. COND. DIAMETER	0.050"
ASSEMBLY	CONDUCTORS ARE PAIRED, TWISTED TOGETHER AND SHIELDED - ALUM SIDE OUT + DRAIN WIRE.
DRAIN	24 AWG 7 X 0.008 (t)
MYLAR	NOTE: CLEAR MYLAR WRAP OVER ALUM. SHIELD & DRAIN.
BRAID	36 AWG SOLID 0.005" 65% COVERAGE
RIPCORD	POLYESTER RIPCORD UNDER JACKET
JACKET	PVC
JACKET THICKNESS	0.023"
FINISHED DIAMETER	0.258"
CSA CERTIFIED	CMG, AWM II
UL RECOGNIZED	CM
FLAME RATING	FT4

The material contained in this document is presented in good faith and believed to be reliable and accurate. However, because testing conditions may vary and material quality or information that may be provided in whole or part by others may be beyond our control, no warranty, expressed or implied, is given and Deca Cables Inc. can assume no liability for results obtained or damages incurred through the application of the data and tests presented.

Rev. 0
2003.06.12