

Description: Four 22 AWG Insulated Conductors
 Overall Foil Shield and TPE Jacket

Date: 9/3/2015

JM Part Number: TBD
Reference:

Component Four 22 AWG Insulated Conductors

Conductor: 22 AWG, 19/34 tinned copper

Insulation: .016" nominal wall of PVC (see color code)

Jacket: .005" nominal wall of Clear Nylon .090"

Cable Construction

Cabling: Four conductors cabled together with FR PP Fillers as needed

Drain Wire: 24 AWG, 7/32 tinned copper

Shield: Aluminum-Mylar tape, Aluminum side IN

Separator: Tissue Tape

Jacket: .072" nominal wall of Black TPE 0.322

Color Code

1. Red 2. Green 3. Black 4. White

Print

E66440 4/C 22 AWG 9\ AWM 20626 90C 600V - - -
LL41103 CSA AWM I/II A/B 90C 600V FT4 - - -
CE ROHS + Sequential Footage Markings

Requirements

Temperature: 90°C
 Voltage: 600V

Approvals: UL AWM Style 20626
 CSA AWM, FT4
 CE-LVD and RoHS Complaint (2011/65/EU)

Written By:	RL	9/3/2015	Rev. 0	Initial Issue
Revised By:				
Revised By:				
Revised By:				