1) CONSTRUCTION:   CONDUCTOR: 16 AWG 19/.0117 STRANDED TINNED COPPER   INSULATION: POLYVINYLCHLORIDE, .016" NOM. WALL THICKNESS   CABLE: (2) COLOR CODED SINGLES TWISTED TOGETHER WITH FILLER AND   WRAPPED WITH A CLEAR POLYESTER BINDER TO FORM A CABLE CORE.   SHIELD: AN OVERALL ALUMINUM POLYESTER FOIL SHIELD (FOIL IN, 100%   COVERAGE) SHALL BE APPLIED OVER THE CABLE CORE AND SHALL			NOM. DIA. .057" .089" .181"	02400	
RIPCORD: JACKET:	INCLUDE A 16 AWG 19/.0117 STRANDED TINNED COPPER DRAIN WIRE IN CONTACT WITH THE METALIZED SURFACE. INCLUDED UNDER JACKET FOR STRIPPING POLYVINYLCHLORIDE, BLUE, .032" NOM. WALL THICKNESS. OVER ALL CABLE DIAMETER			.184" .248"	
	E RATING, MAX. E RATING, MIN.	105°C -20°C 43.8 LBS.			
3) ELECTRICAL CHARACTERISTICS: CAPACITANCE, MUTUAL, NOM. CAPACITANCE, GROUNDED, NOM. DIELECTRIC WITHSTANDING, MIN. VOLTAGE RATING, MAX. D.C. RESISTANCE, MAX. PER ASTM B286		47 PF/FT. 87 PF/FT. 2000V RMS 600V 4.82 Ω/1000'			
4) AGENCY APPROVA CSA AWM FT4 UL AWM STYLE	ALS: E 2586 105C 600V				
	ONTROLS, MEDICAL ELECTR ABLE IS REQUIRED. RoHS CO			COMPACT	
6) PRINT: 600V-TROL <sup>®</sup>	E69976 <b>RJ</b> AWM 2586 VW-1	CSA LL51726 AWM	/II A/B 105C 600V FT4 <b>(I</b>	LOT DESIGNATO	R)
7) COLOR CODE: 1. BLACK 2. BROWN		JACKET			
STANDARD PA	GED AS PER QWC'S CKAGING	DRAIN SHIELD INSULATION CONDUCTOR BINDER FILLER RIP CORD	Created 1 12/14/12 DRAWN: 03/10/16 REV. 02 CHECKED: GBM TITLE 600V-TROL® 2/C 16		E
CUSTOMER APPROVAL:		DATE:	CSA AWM FT4 CABLE		

DOCUMENT #0040 05/26/11 This document contains proprietary and confidential information which is the property of Quabbin Wire & Cable Co., Inc. and may not be copied or disclosed to others without the express written permission of Quabbin Wire & Cable Co., Inc.