

529 Thomas Dríve, Bensenville, IL 60106 | TF: 888.518.8086 | FX: 630.860.5944

Specification Sheet

Lake Cable Part #: V123(19)/X

Description: 12 AWG 3 conductor 19 strand bare copper with polyvinylchloride and nylon insulation, unshielded with an overall PVC jacket 600V control tray cable, approved for use in SUN RES DIR BUR 90°C applications.

Nylon

1. Conductor

1.1. AWG Size & Stranding: 12 AWG 19 Strands Class C

1.2. Material: Annealed Bare Copper

1.3. Conductor Count: 3 Conductors

2. Insulation

2.1. Material:	Polyvinylchloride & Nylon
2.2. Wall Thickness:	0.015" PVC & 0.005" Nylor
2.3. Color Code:	Black, White, Green

3. Assembly

3.1. Lay Length:	4.50" LHL
3.2. Fillers:	N/A
3.3. Binder:	N/A
3.4. Shield:	N/A
3.5. Drain Wire:	N/A

Your signature constitutes that you have read and agreed to this specification sheet and upon confirmation of your order; this item may be non-cancelable and non-returnable. Signatur Company

4. Jacket

4.1. Material:	Polyvinylchloride
4.2. Wall Thickness:	0.045"
4.3. Diameter:	0.371" ± 0.030"
4.4. Color:	Black
4.5. Ripcord:	Yes
4.6. Cold Bend Rating:	-40°C
4.7. Weight:	105 lbs./Mft.

5. Markings

5.1. Type:	Cable shall be permanently identified via surface inkjet print
5.2. Legend:	LAKE CABLE E208309 12AWG 3C (UL) TC-ER THWN-2/VW-1 600V 90°C DRY/WET
	PVC JACKET SUN RES DIR BUR FT4 "ROHS II" MADE IN USA

5.3. Footage Markers:

6. Standards

6.1. Refer to NEC (NFPA 70) article 336 for installation guidelines

Yes

- 6.2. Cable is suitable for use in Class I Division 2 hazardous locations
- 6.3. Individual conductors pass UL VW-1 flame test, rated THWN-2/VW-1
- 6.4. UL listed as Type TC-ER per UL Standard 1277 for tray cables
- 6.5. UL approved for Direct Burial and Sunlight Resistant applications
- 6.6. Cable meets UL 1581 & 1202 (FT-4) 70,000 BTU/HR & ICEA T-29-520 210,000 BTU/HR requirements
- 6.7. Meets ICEA S-73-532, where applicable
- 6.8. All materials used in the manufacture of this cable are RoHS II & REACH compliant
- 6.9. Made in the USA

ALL SPECIFIED PARAMETERS ARE NOMINAL AND SUBJECT TO VERIFICATION