

# **Specification Sheet**

## Lake Cable Part #: VXC105LCU

**Description:** 10 AWG 5 conductor 7 strand bare copper with XLPE insulation, a corrugated bare copper tape shield and an overall CPE jacket 600V control tray cable, approved for use in SUN RES DIR BUR OIL RES I & II 90°C applications.

## 1. Conductor

1.1. AWG Size & Stranding:	10 AWG 7 Strands Class B
1.2. Material:	Annealed Bare Copper
1.3. Conductor Count:	5 Conductors

## 2. Insulation

2.1. Material:	Cross-linked Polyethylene
2.2. Wall Thickness:	0.030"
2.3. Color Code:	Method 1, Table E-2

#### 3. Assembly

3.1. Lay Length:	Per UL Standard 1277
3.2. Fillers:	Non-Hygroscopic Polypropylene - as
	Required for a Circular Cross-Section
3.3. Binder:	Clear Mylar
3.4. Shield:	0.005" Corrugated Bare Copper Tape -
	20% minimum overlap
3.5. Drain Wire:	N/A

Your signature constitutes that you have read and agreed to this specification sheet and upon confirmation of your order; this item may be non-cancelable and non-returnable.

Signature

Company

#### 4. Jacket

<ul> <li>4.1. Material:</li> <li>4.2. Wall Thickness:</li> <li>4.3. Diameter:</li> <li>4.4. Color:</li> <li>4.5. Ripcord:</li> <li>4.6. Cold Bend Rating:</li> </ul>	Chlorinated Polyethylene 0.060" 0.668" Black Yes -25°C
4.7. Weight:	373 Lbs/Mft

## 5. Markings

5.1. Type:	Cable permar	nently identifie	ed via surface	inkjet print		
5.2. Legend:	LAKE CABLE E	208309 10AW	G 5C (UL) TC-	ER XHHW-2/W	/W-1 600V 9	0'C DRY/WET
-	CORRUATGED	BARE COPPER	TAPE SHIELD	CPE JACKET	SUN RES DIF	BUR OIL RES
	I & II FT4	"ROHS"				
5.3. Footage Markers:	Yes					

## 5.3. Footage Markers:

#### 6. Standards

- 6.1. Refer to NEC (NFPA 70) article 336 for installation guidelines
- 6.2. Cable is suitable for use in Class I Division II hazardous locations
- 6.3. Individual conductors pass UL VW-1 flame test, rated XHHW-2/VW-1
- 6.4. UL listed as Type TC-ER per UL Standard 1277 for tray cables
- 6.5. UL approved for Direct Burial, Sunlight and Oil I & II Resistant applications
- 6.6. Cable meets UL 1581 & 1202 (FT-4) 70,000 BTU/HR & ICEA T-29-520 210,000 BTU/HR requirements
- 6.7. Meets ICEA S-73-532, where applicable
- 6.8. All materials used in the manufacture of this cable are RoHS compliant
- 6.9. Made in the USA

#### ALL SPECIFIED PARAMETERS ARE NOMINAL AND SUBJECT TO VERIFICATION