

Product Specification



Part No.: B2587663		Color																																							
<p style="text-align: center;">Cross Section</p>		Insulation 1.Black 2.Orange 3.Red 4.Green/Yellow Note:"Green/Yellow" means Green is the base color of the wire and Yellow is the stripe color.																																							
		Jacket According to the Customer's requirement.																																							
<p style="text-align: center;">Marking</p> BELDEN E357312-S 4C14 SHIELDED AWM STYLE 2587 90C 600V VW-1 - - - c AWM I/II A/B 90C 600V FT4 ROHS 2280879-6		Performance																																							
		Electrical Characteristics: Max. Conductor DC Resistance at 20°C (Ω/km) 8.6 Dielectric Strength(kV/min), AC 2.0																																							
Description		Mechanical Characteristics: <table border="1"> <thead> <tr> <th>Test Object</th> <th>Insulation</th> <th>Jacket</th> </tr> </thead> <tbody> <tr> <td>Test Material</td> <td>PVC</td> <td>PVC</td> </tr> <tr> <td>Before Tensile Strength (Mpa)</td> <td>≥ 10.3</td> <td>≥ 10.3</td> </tr> <tr> <td>Aging Elongation (%)</td> <td>≥ 100</td> <td>≥ 100</td> </tr> <tr> <td>Aging Condition (°C)</td> <td colspan="2">121±2°C X 168 hrs</td> </tr> <tr> <td>After Tensile Strength (Mpa)</td> <td>≥ 70% of original</td> <td>≥ 70% of original</td> </tr> <tr> <td>Aging Elongation (%)</td> <td>≥ 65% of original</td> <td>≥ 65% of original</td> </tr> </tbody> </table>		Test Object	Insulation	Jacket	Test Material	PVC	PVC	Before Tensile Strength (Mpa)	≥ 10.3	≥ 10.3	Aging Elongation (%)	≥ 100	≥ 100	Aging Condition (°C)	121±2°C X 168 hrs		After Tensile Strength (Mpa)	≥ 70% of original	≥ 70% of original	Aging Elongation (%)	≥ 65% of original	≥ 65% of original																	
Test Object	Insulation			Jacket																																					
Test Material	PVC	PVC																																							
Before Tensile Strength (Mpa)	≥ 10.3	≥ 10.3																																							
Aging Elongation (%)	≥ 100	≥ 100																																							
Aging Condition (°C)	121±2°C X 168 hrs																																								
After Tensile Strength (Mpa)	≥ 70% of original	≥ 70% of original																																							
Aging Elongation (%)	≥ 65% of original	≥ 65% of original																																							
Rated Voltage (V) 600 Rated Temperature (°C) 90 Product Standard Certification UL Flammability Test UL VW-1&CSA FT4																																									
Application For internal or external wiring of electronic equipment																																									
Reference Standard UL758, UL1581 & CSA C22.2 No.210.2																																									
Construction																																									
4 Cores <table border="1"> <thead> <tr> <th>Conductor</th> <th>Stranded Bare Copper</th> </tr> </thead> <tbody> <tr> <td>AWG</td> <td>14</td> </tr> <tr> <td>Construction</td> <td>41/0.254</td> </tr> <tr> <td>Stranded Dia. (mm)</td> <td>1.88</td> </tr> <tr> <td>Insulation</td> <td>PVC</td> </tr> <tr> <td>Min. Thickness (mm)</td> <td>0.61</td> </tr> <tr> <td>Nom. Thickness (mm)</td> <td>0.76</td> </tr> <tr> <td>Insulation Dia. (±0.12mm)</td> <td>3.40</td> </tr> <tr> <td>Assembly</td> <td>4C+Filler</td> </tr> <tr> <td>Direction</td> <td>S</td> </tr> <tr> <td>PAP tape(Overlap,%)</td> <td>≥25</td> </tr> <tr> <td>Braid Shield</td> <td>Tinned Copper</td> </tr> <tr> <td>Construction(mm)</td> <td>24/7/0.16</td> </tr> <tr> <td>Coverage(%)</td> <td>≥85</td> </tr> <tr> <td>Non-woven tape(overlapping)</td> <td>≥25%</td> </tr> <tr> <td>Jacket</td> <td>PVC</td> </tr> <tr> <td>Min. Thickness (mm)</td> <td>0.76</td> </tr> <tr> <td>Nom. Thickness (mm)</td> <td>1.09</td> </tr> <tr> <td>Dia. (±0.40mm)</td> <td>11.20</td> </tr> </tbody> </table>		Conductor	Stranded Bare Copper	AWG	14	Construction	41/0.254	Stranded Dia. (mm)	1.88	Insulation	PVC	Min. Thickness (mm)	0.61	Nom. Thickness (mm)	0.76	Insulation Dia. (±0.12mm)	3.40	Assembly	4C+Filler	Direction	S	PAP tape(Overlap,%)	≥25	Braid Shield	Tinned Copper	Construction(mm)	24/7/0.16	Coverage(%)	≥85	Non-woven tape(overlapping)	≥25%	Jacket	PVC	Min. Thickness (mm)	0.76	Nom. Thickness (mm)	1.09	Dia. (±0.40mm)	11.20		
Conductor	Stranded Bare Copper																																								
AWG	14																																								
Construction	41/0.254																																								
Stranded Dia. (mm)	1.88																																								
Insulation	PVC																																								
Min. Thickness (mm)	0.61																																								
Nom. Thickness (mm)	0.76																																								
Insulation Dia. (±0.12mm)	3.40																																								
Assembly	4C+Filler																																								
Direction	S																																								
PAP tape(Overlap,%)	≥25																																								
Braid Shield	Tinned Copper																																								
Construction(mm)	24/7/0.16																																								
Coverage(%)	≥85																																								
Non-woven tape(overlapping)	≥25%																																								
Jacket	PVC																																								
Min. Thickness (mm)	0.76																																								
Nom. Thickness (mm)	1.09																																								
Dia. (±0.40mm)	11.20																																								
		Sample Record																																							
		Sample No. : Original spec no.: Rev.: Ref. spec No. : SK-B2587-663 Rev.: 0																																							
		Revision History																																							
		Prepared by: YANGHUA 2012/11/23 Table No.:T100 Rev.: 0 Approved by: CICI CHENG 2012/11/23 Page 1 of 1																																							