



Specification Sheet

Lake Cable Part #: V102(19)

Description: 10 AWG 2 conductor 19 strand bare copper with polyvinylchloride and nylon insulation, unshielded with an overall PVC jacket 600V control tray cable, approved for use in SUN RES DIR BUR 90°C applications.

1. Conductor

- 1.1. AWG Size & Stranding: 10 AWG 19 Strands Class C
- 1.2. Material: Annealed Bare Copper
- 1.3. Conductor Count: 2 Conductors

2. Insulation

- 2.1. Material: Polyvinylchloride & Nylon
- 2.2. Wall Thickness: 0.020" PVC & 0.005" Nylon
- 2.3. Color Code: Method 1, Table E-2

3. Assembly

- 3.1. Lay Length: 5.00" (2.40 Tw/ft) LHL
- 3.2. Fillers: N/A
- 3.3. Binder: N/A
- 3.4. Shield: N/A
- 3.5. Drain Wire: N/A

4. Jacket

- 4.1. Material: Polyvinylchloride
- 4.2. Wall Thickness: 0.045"
- 4.3. Diameter: 0.426" ± 0.035"
- 4.4. Color: Black
- 4.5. Ripcord: Yes
- 4.6. Cold Bend Rating: -40°C
- 4.7. Weight: 117 lbs./Mft.

5. Markings

- 5.1. Type: Cable shall be permanently identified via surface inkjet print
- 5.2. Legend: LAKE CABLE E208309 10AWG 2C (UL) TC THWN-2/VW-1 600V 90°C DRY/WET PVC JACKET SUN RES DIR BUR FT4 "ROHS II" MADE IN USA
- 5.3. Footage Markers: Yes

6. Standards

- 6.1. Refer to NEC (NFPA 70) article 336 for installation guidelines
- 6.2. Cable is suitable for use in Class I Division II hazardous locations
- 6.3. Individual conductors pass UL VW-1 flame test, rated THWN-2/VW-1
- 6.4. UL listed as Type TC per UL Standard 1277 for tray cables
- 6.5. UL approved for Direct Burial and Sunlight Resistant applications
- 6.6. Cable meets UL 1581 & 1202 (FT-4) 70,000 BTU/HR & ICEA T-29-520 210,000 BTU/HR requirements
- 6.7. Meets ICEA S-73-532, where applicable
- 6.8. All materials used in the manufacture of this cable are RoHS II & REACH compliant
- 6.9. Made in the USA

ALL SPECIFIED PARAMETERS ARE NOMINAL AND SUBJECT TO VERIFICATION

Your signature constitutes that you have read and agreed to this specification sheet and upon confirmation of your order; this item may be non-cancelable and non-returnable.

Signature

Company