

Specification Sheet

Lake Cable Part #: VXC102T

Description: 10 AWG 2 conductor 7 strand tinned copper with XLPE insulation, unshielded with an overall CPE jacket 600V control tray cable, approved for use in SUN RES DIR BUR OIL RES I & II 90°C applications.

1. Conductor

1.1. AWG Size & Stranding: 10 AWG 7 Strands Class B Annealed Tinned Copper 1.2. Material: 1.3. Conductor Count: 2 Conductors

2. Insulation

2.1. Material: Cross-linked Polyethylene 2.2. Wall Thickness: 0.030" Method 1, Table E-2 2.3. Color Code:

3. Assembly

3.1. Lay Length:	5.25" LHL
3.2. Fillers:	Non-Hygroscopic Polypropylene - As
	required for a circular cross-section
3.3. Binder:	Clear Mylar

3.3. Binder:

4. Jacket

4.1. Material:	Chlorinated Polyethylene
4.2. Wall Thickness:	0.045"
4.3. Diameter:	0.443" +/- 0.035"
4.4. Color:	Black
4.5. Ripcord:	Yes
4.6. Cold Bend Rating:	-25°C
4.7. Weight:	135 lbs./Mft.
· ·	

Your signature constitutes that you have read and agreed to this specification sheet and upon confirmation of your order; this item may be non-cancelable and non-returnable.

Signature

Company

Date

5. Markings

5.1. Type: Cable shall be permanently identified via surface inkjet print LAKE CABLE E208309 10AWG 2C (UL) TC XHHW-2/VW-1 600V 90°C DRY/WET 5.2. Legend: CPE JACKET SUN RES DIR BUR OIL RES I & II FT4 "ROHS II" MADE IN USA 5.3. Footage Markers: Yes

6. Standards

- 6.1. Refer to NEC (NFPA 70) article 336 for installation guidelines
- 6.2. Cable is suitable for use in Class I Division 2 hazardous locations
- 6.3. Individual conductors pass UL VW-1 flame test, rated XHHW-2/VW-1
- 6.4. UL listed as Type TC per UL Standard 1277 for tray cables
- 6.5. UL approved for Direct Burial, Sunlight and Oil I & II Resistant applications
- 6.6. Cable meets UL 1581 & 1202 (FT-4) 70,000 BTU/HR & ICEA T-29-520 210,000 BTU/HR requirements
- 6.7. Meets ICEA S-73-532, where applicable
- 6.8. All materials used in the manufacture of this cable are RoHS II & REACH compliant
- 6.9. Made in the USA

ALL SPECIFIED PARAMETERS ARE NOMINAL AND SUBJECT TO VERIFICATION