## UNIFIED WIRE & CABLE, INC. DEKALB, ILLINOIS 60115 SPECIFICATION SHEET PN:1441T3173-X 14(41X30)TC UL 3173/SIS CL1251 VW-1 REACH/ROHS COMPLIANT

**COPPER:** 14 41X30 TINNED COPPER 1 ½" MAX LAY LENGTH

BASIC SPECIFICATION ASTM B-33 & B-174

.074 NOMINAL DIAMETER (INCHES)

NOMINAL DIAMETER OF INDIVIDUAL STRANDS .010 (INCHES)

APPROXIMATE CIRCULAR MIL AREA 4110

MAXIMUM DC RESISTANCE 2.94 OHMS/1000' AT 20 C

**INSULATION:** CHEMICALLY CROSSLINKED THERMOSETTING POLYETHYLENE

MANUFACTURED TO UL 3173 CL 1251

3173 RATED AT 125 C 600 VOLTS

RATED 90C IN DRY LOCATIONS WHEN USED AS SIS

.030 MIL MIN AVG WALL THICKNESS .027 MIL MIN AT ANY POINT

MEETS UL VW-1 FLAME TEST

**FINISHED O.D.:** .134 NOMINAL DIAMETER ( +/- .003)

**PACKAGING:** REELS OR DRUMS

STANDARDS: MANUFACTURED PER UL 758 CSA 22.2 No 127 & 210-05

**USAGE:** (AS DEFINED BY UL) INTERNAL WIRING OF APPLIANCES

FOR USE AS SWITCHBOARD WIRING.