

## Specification Sheet

## Lake Cable Part #: C183(41)/2517

Description: 18 AWG 3 conductor 41 strand bare copper wire with PVC insulation, unshielded and an overall

PVC jacket.

1. Conductor

1.1.AWG Size & Stranding: 18 AWG 41 Strands Class M 1.2.Material: Annealed Bare Copper

1.3. Conductor Count: 3 Conductors

2. Insulation

2.1. Material: Polyvinylchloride

2.2. Wall Thickness: 0.012"

2.3.Color Code: Black, White, Red

3. Assembly

3.1. Nominal Lay Length: 2.00" LHL (6 Tw/Ft)

3.2.Shield: N/A 3.3.Drain Wire: N/A

3.4. Separtator: Tissue Wrap - 100% Coverage

4. Jacket

4.1. Material: Pressure Extruded Polyvinylchloride

4.2. Wall Thickness: 0.036"

4.3. Diameter: 0.225" ± 0.005"

4.4.Color: Black 4.5.Ripcord: No

4.6. Weight: 35 Lbs/Mft

5. Markings

5.1. Type: Cable permanently identified via surface inkjet print

5.2.Legend: LAKE CABLE E206787 18AWG 3C 9U AWM 2517 300V 105C OR CSA LL226471

AWM I/II A/B 105C 300V FT1 FT2 -40C "O" "ROHS COMPLIANT"

MADE IN USA

5.3. Footage Markers: Yes

## 6. Standards

- 6.1.UL recognized component as type AWM 2517 per UL standard 758
- 6.2. Insulated conductors are UL recognized component as type AWM 1731 per UL standard 758
- 6.3.CSA recognized component as AWM I/II A/B 105'C 300V FT1 FT2 per CSA standard 22.2 No. 210-11
- 6.4. Cable meets RoHS 2002/95/EC Directive, RoHS 2 2011/65/EU Directive, RoHS 3 2015/863/EU Directive
- 6.5. Cable is REACH compliant per Regulation (EC) No 1907/2006 (197) Updated January 15, 2019
- 6.6. Operating Voltage: 300V RMS
- 6.7. Made in the USA
- 6.8. WARNING: This product may contain chemicals, such as Vinyl Chloride, known to the state of California to cause cancer. For more information, go to <a href="https://www.P65Warnings.ca.gov">www.P65Warnings.ca.gov</a>. Wash hands after handling

ALL SPECIFIED PARAMETERS ARE NOMINAL AND SUBJECT TO VERIFICATION

you have read and agreed to this specification sheet and upon confirmation of your order; this item may be non-cancelable and non-returnable.
Signature
Company
Date

Your signature constitutes that