

UNIFIED WIRE & CABLE , INC.
DEKALB, ILLINOIS 60115
SPECIFICATION SHEET
PN:1626T3173VW-X
16 26X30 TC UL 3173 VW-1 CSA CL 1251 FT2
ROHS COMPLIANT

- COPPER:** 16 26X30 TINNED COPPER 1 1/4" MAX LAY LENGTH
- BASIC SPECIFICATION ASTM B -174
.059 NOMINAL DIAMETER (INCHES)
NOMINAL DIAMETER OF INDIVIDUAL STRANDS .010 (INCHES)
APPROXIMATE CIRCULAR MIL AREA 2580
- INSULATION:** CHEMICALLY CROSSLINKED THERMOSETTING POLYETHYLENE
MANUFACTURED TO UL 3173 CL 1251
RATED AT 125 C 600 VOLTS
.030 MIL MIN AVG WALL THICKNESS .027 MIL MIN AT ANY POINT
MEETS UL VW-1 FLAME TEST
- FINISHED O.D.:** .119 NOMINAL DIAMETER
- PACKAGING:** REELS OR DRUMS
- STANDARDS:** MANUFACTURED TO UL 758 CSA 22.2 No 127 & 210-05
- USAGE:** (AS DEFINED BY UL) INTERNAL WIRING OF APPLIANCES.
SUITABLE FOR SWITCHBOARD WIRING