

# THERM-O-LINK INC.

10513 Freedom Street  
GARRETTSVILLE, OHIO 44231

(330) 527-2124  
FAX: (330) 527-2123

## Material Specification

Customer: IEWC

TOL Part Number: XFF/3321-14-1002  
Spec Revision Level: A6

Description: 14 GA AWM ULXFF/3321 150 DEGC 300V/600V XLPE  
41 STRANDS TINNED

Conductor (Stranding): 41 x 30 AWG Tinned Copper  
Conductor OD (Nom) 0.069 inches  
Max. Lay Length: 2.0 inch Lay  
Min Avg Wall Thickness: 0.030 inches  
Nom. O. D: 0.132 inches  
Min O. D: 0.129 inches  
Max Runout: 0.008 inches  
Insulation Strip Limits: 5 lb (min)- 20 lb (max)  
Circular Mils (CMA): 3987 (Min)  
Surface Print: 14 AWG (UL) TYPE XFF 150C 300V E1162 OR AWM  
STYLE 3321 150C XLPE 600V CSA CL1503 OR AWM  
I A 150C 600V FT2 LL12201

This Product is RoHS Compliant.

### Specification Reference Data

SAE: N/A	Ford: N/A	Chrysler: N/A
UL : AWM 3321/ STD 758	CSA: C22.2 #210-05	Packard: N/A
Other: N/A		

Therm-O-Link, Inc. certifies that the above specifications are met or exceeded in the production of this product.

Verified By:

Mir Hussain (Corporate Quality Engineer)

Date: 8-26-2016