



ATLAS WIRE CORPORATION
 9525 RIVER STREET
 SCHILLER PARK, ILLINOIS 60176
 (847) 678-1210
 (847) 678-1281 FAX
 www.atlaswirecorp.com



Atlas Wire Corporation
 Registered to ISO9001 and TS16949
 Schiller Park, IL 60176
 Reference No. 10000854
 Tucson, AZ 85714
 Reference No. 10003647

MATERIAL SPECIFICATION SHEET

#16 19/29 TC .010" PVC
RoHS Compliant
MIL-16878/1 TYPE B
105c - 600 VOLTS

CONDUCTOR:	#16 19/29 TINNED COPPER 3/4" UNILAY	
	NOMINAL O.D.	.057"
	APPROXIMATE CIRCULAR MILL AREA	2.409
	WEIGHT PER THOUSAND FEET	7.50#
	BASIC SPECIFICATION	ASTM B-8 ASTM B-286
PVC:	TEMPERATURE RATING	105c
	VOLTAGE RATING	600 VOLTS
	ELONGATION	300% AVG.
	SPECIFIC GRAVITY	1.34
	DUROMETER (SHORE)	47 (D)
	TENSILE STRENGTH	3000 PSI AVG
	SPARK TESTED	5,700 VOLTS
	OXYGEN INDEX	25
	BRITTLE POINT	-29c
	FINISHED O.D.	.077"
WEIGHT PER 1,000 FEET	8.76#	

REVISION: MIL-DTL- 16878G - PRINT REQUIRED*

* OUR STANDARD IS PRINTED, IF NO PRINTING IS PREFERRED
 PLEASE CALL THAT OUT AT TIME OF ORDER.