



**Quality Assurance
Test Certificate As To Quality
Certificate of Compliance**

Report No. 67826

IEWC INC
5001 S TOWNE DR
PO BOX 510908
NEW BERLIN WI 53151-0908

Customer Order No. 4500290959
General Cable Order No. 83056-00
Catalog No. 12211.711100

The following is a true and accurate description of the material manufactured at our Marion Plant, and shipped on the above order.

<u>Item No.</u>	<u>Quantity</u>	<u>Description</u>	<u>Applicable Specification</u>
4.00-13.00	128414	10 AWG 1/C 19/W COATED SOFT COPPER, .030" EP, .030" XL-CPE, TYPE USE-2, RHH OR RHW-2 600 VOLTS UL TYPE PV - PHOTOVOLTAIC WIRE	ICEA S-95-658

RoHS COMPLIANT

I hereby certify that the material described above was inspected under my general supervision and found to comply with the requirements of applicable spec as interpreted by General Cable Quality Control Procedures prior to being placed into stock or released for shipment.

Test records will be kept on file at least one year from date of test, and will be made available for examination by authorized persons upon request.

A handwritten signature in black ink, appearing to read 'S. [unclear]', is written over a horizontal line.

Quality Assurance Manager
Date: August 8, 2012