

UNIFIED WIRE & CABLE , INC.  
DEKALB, ILLINOIS 60115  
**SPECIFICATION SHEET**  
**PN:1626B3173-X**  
**16(26X30)BC UL 3173 CL 1251 FT2**  
ROHS & REACH COMPLIANT

**COPPER:** 16(26X30) BARE COPPER 1 1/4" LAY LENGTH

BASIC SPECIFICATION ASTM B -174  
.059 NOMINAL DIAMETER (INCHES)  
NOMINAL DIAMETER OF INDIVIDUAL STRANDS .010 (INCHES)  
APPROXIMATE CIRCULAR MIL AREA 2580

**INSULATION:** CHEMICALLY CROSSLINKED THERMOSETTING POLYETHYLENE  
MANUFACTURED TO UL 3173 CL 1251  
RATED AT 125 C 600 VOLTS ALSO RATED SUITABLE FOR SWITCHBOARD WIRING  
.030 MIL MIN AVG WALL THICKNESS .027 MIL MIN AT ANY POINT  
SPECIFIC GRAVITY 1.40 (+/- .02) ASTM D- 792 TEST METHOD  
TENSILE STRENGTH, ORIGINAL 3000 ASTM D- 412 TEST METHOD  
ELONGATION, ORIGINAL 220 ASTM D- 412 TEST METHOD

**FINISHED O.D.:** .120 NOMINAL DIAMETER ( +/- .003)

**PACKAGING:** REELS OR DRUMS

**USAGE:** (AS DEFINED BY UL) INTERNAL WIRING OF APPLIANCES.

SUITABLE FOR SWITCHBOARD WIRING