

UNIFIED WIRE & CABLE , INC.
DEKALB, ILLINOIS 60115
SPECIFICATION SHEET
PN:1441T3173-X
14(41X30)TC UL 3173/SIS CL1251 FT2
REACH/ROHS COMPLIANT

- COPPER:** 14 41X30 TINNED COPPER 1 ½” MAX LAY LENGTH
- BASIC SPECIFICATION ASTM B-33 & B -174
.074 NOMINAL DIAMETER (INCHES)
NOMINAL DIAMETER OF INDIVIDUAL STRANDS .010 (INCHES)
APPROXIMATE CIRCULAR MIL AREA 4110
MAXIMUM DC RESISTANCE 2.94 OHMS/1000' AT 20 C
- INSULATION:** CHEMICALLY CROSSLINKED THERMOSETTING POLYETHYLENE
MANUFACTURED TO UL 3173 CL 1251
3173 RATED AT 125 C 600 VOLTS
RATED 90C IN DRY LOCATIONS WHEN USED AS SIS
.030 MIL MIN AVG WALL THICKNESS .027 MIL MIN AT ANY POINT
MEETS UL HORIZONTAL FLAME TEST
- FINISHED O.D.:** .134 NOMINAL DIAMETER (+/- .003)
- PACKAGING:** REELS OR DRUMS
- STANDARDS:** MANUFACTURED PER UL 758 CSA 22.2 No 127 & 210-05
- USAGE:** (AS DEFINED BY UL) INTERNAL WIRING OF APPLIANCES
FOR USE AS SWITCHBOARD WIRING.