APPLIANCE WIRING MATERIAL

Subj.758 Section 1 Page 1110 Issued:1959-05-01

Revised:2014-06-16

Style 1110 Single-conductor cable using Non-Integral Jacket

Rating	105 deg C, 300 Vac or 600 Vdc, Horizontal Flame.
Conductor	26 AWG - 16 AWG, Solid or Stranded.
Insulated Conductor	Labeled or complying with manufacturer's AWM procedure, or Extruded PVC, 15 mils minimum average thickness, 13 mils minimum thickness at any point.
Shield	Optional.
Jacket	Extruded PVC, 15 mils minimum average thickness, 12 mils minimum thickness at any point.
Standard	Appliance Wiring Material UL 758.
Marking	General.
Use	Internal Wiring.

UL and the UL Logo are trademarks of UL LLC $\ensuremath{\text{@}}\xspace 2017$