				(Սլ)
APPLIANCE WIRING MATERIAL				
Subj.758 S		Section 3	Page 3069	Issued:1959-05-01 Revised:2014-07-02
Styl	e 3069	Single conductor with insulation and other-than- extruded covering		
	Rating	150 deg C, 600 Vac, Horizontal flame.		
	Conductor	26 AWG - 20 AWG, solid or stranded.		
	Insulation	Extruded SR, 30 mils minimum average thickness, 27 mils minimum thickness at any point.		
	Covering	Same as for Type SF-2 Fixture Wire.		
	Standard	Appliance Wiring Material UL 758.		
	Marking	General	General.	
	Use	Interna	l wiring.	

UL and the UL Logo are trademarks of UL LLC $\ensuremath{\mathbb C}$ 2017