



APPLIANCE WIRING MATERIAL

Subj.758

Section 3

Page 3125

Issued:1960-08-25

Revised:2012-04-26

Style 3125

Single conductor wire using other-than-extruded covering.

Rating 200 deg C, 600 Vac, Horizontal Flame.

Conductor 8 AWG - 2 AWG, stranded, consisting of 26 AWG or larger strands.

Insulation Extruded SR, 60 mils minimum average thickness, 54 mils minimum at any point.

Covering Glass fiber braid, 16 or 24 carriers, 150-1/3 glass.

<u>Glass fiber AWG size</u>	<u>Number of ends</u>	<u>Minimum picks per inch</u>
8	3	12.0
6	4	10.5
4	4	12.0
3	5	10.5
2	5	10.5

Treatment of fibrous covering shall be the same as for Type SF-2.

Standard Appliance Wiring Material UL 758.

Marking General.

Use Lead wire for hazardous location motors or internal wiring of appliances.

UL and the UL Logo are trademarks of UL LLC © 2017