



APPLIANCE WIRING MATERIAL

Subj.758

Section 3

Page 3290

Issued:1975-02-06

Revised:2012-03-12

Style 3290

Single Conductor with Extruded Insulation

Rating	125 deg C, 600 Vac, Horizontal flame.
Conductor	26 AWG - 9 AWG solid or stranded round, tinned or bare.
Insulation	Extruded XLPE, 60 mils minimum average thickness, 54 mils minimum thickness at any point. See facing page for compound identification.
Standard	Appliance Wiring Material UL 758.
Marking	General.
Use	Internal Wiring of Heat Pumps and Refrigerating Equipment.

UL and the UL Logo are trademarks of UL LLC © 2017