



APPLIANCE WIRING MATERIAL

Subj.758

Section 3

Page 3740

Issued:2004-10-18

Revised:2012-04-05

Style 3740

Single Conductor with Extruded Insulation

Rating 180 deg C, 600 Vac, Horizontal flame.

Conductor 50-4/0 AWG solid or stranded.

Insulation Extruded XLPVDF

<u>50-10 AWG conductor size</u>	<u>16 mils minimum average thickness</u>	<u>14 mils minimum thickness at any point</u>
9-2 AWG	24 avg	22 min
1-4/0 AWG	30 avg	27 min

See the Facing Page for the Compound Designation.

Standard Appliance Wiring Material UL 758.

Marking General.

Use Internal Wiring.

UL and the UL Logo are trademarks of UL LLC © 2017