2	IG MATERIAL Section 3 Page 3127 Single conductor cable with e:	Issued:1960-08-25 Revised:2012-03-09 xtruded insulation
Rating	150 deg C, 600 Vac, Horizontal flame.	
Conductor	8 AWG - 2 AWG stranded copper, coated with tin, nickel, or silver; strands 30 AWG, or larger.	
Insulation	Extruded SR, 60 mils minimum average thickness, 54 mils minimum thickness at any point.	
Covering	AWG, 3 ends, 12 picks per per in; 4 AWG, 4 ends, 12 ends, 10.5 picks per in;	riers, 150-1/3 glass: for 8 in; 6 AWG, 4 ends, 10.5 picks .0 picks per in; 3 AWG, 5 2 AWG, 5 ends, 10.5 picks per Covering of Same as for Type
Standard	Appliance Wiring Material	UL 758.
Marking	General.	
Use	Leads for hazardous locat of Appliances.	ion motors or Internal Wiring

UL and the UL Logo are trademarks of UL LLC  $\circledcirc$  2017