APPLIANCE WIRING MATERIAL

Subj.758 Section 3 Page 3172

Issued:1962-07-10 Revised:2012-03-23

Style 3172 Single Conductor with Extruded Insulation and Non-Extruded Covering

Rating	200 deg C, 600 Vac, Horizontal flame.
Conductor	26 AWG - 18 AWG, solid or stranded.
Insulation	Extruded Silicone Rubber, 30 mils minimum average thickness, 27 mils minimum thikcness at any point.
Covering	Same as for Type SF-2 Fixture Wire. One or more glass or aramid braid fibrous coverings.
Standard	Appliance Wiring Material UL 758.
Marking	General.
Use	Internal wiring of appliances.

UL and the UL Logo are trademarks of UL LLC $\ensuremath{\text{@}}\xspace$ 2017